



NOTES:

- A. WORK ON HYDRO POLE TO BE CO-ORDINATED WITH AND IN THE PRESENCE OF THE LOCAL HYDRO AUTHORITY. PROVIDE TWO WEEKS ADVANCE NOTICE TO THE LOCAL HYDRO AUTHORITY ONCE THE NEW SERVICE HAS PASSED THE ONTARIO HYDRO INSPECTION.
- B. MOUNTING DETAILS SHOWN ARE TYPICAL ONLY AND SHALL BE ADAPTED TO SUIT SITE CONDITIONS.
- C. WOOD MOULDING WITH STAPLES SHALL BE USED ON WOOD POLES. FOR CONCRETE POLES USE 13 DIA. SHALL BE ADAPTED TO SUIT SITE CONDITIONS AND RIGID PVC CONDUIT SUPPORTED BY STAINLESS STEEL BANDING EVERY 1200.
- D. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH STANDARD DRAWING 4-1-4

ALL DIMENSIONS IN MILLIMETRES
UNLESS OTHERWISE NOTED



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: DECEMBER 2018

APPROVED BY:

DRAWN BY

GK

TSS SECTION

STD. DWG. NUMBER

SCALE

4-1-1

N.T.S.

**ON POLE POWER SUPPLY
WOOD/CONCRETE POLE MOUNTED
TRAFFIC SIGNAL & STREETLIGHT APPLICATION**