



DELETED  
(REFER TO SECTION 2-5)

NOTES FOR FLEXIBLE PIPE

1. OBVERT OF DROP PIPE TO MEET THE OBVERT OF THE RECEIVING SEWER.
2. DROP PIPE TO BE ONE SIZE SMALLER THAN THE INCOMING SEWER, MINIMUM SIZE 250mm.
3. STAINLESS STEEL STRAPS WITH SPACERS (45mm), AND MAXIMUM SPACING OF 1800mm.
4. INTERNAL DROP ASSEMBLY TO BE USED ON EXISTING STRUCTURES ONLY.
5. SAFETY PLATFORMS TO BE LOCATED ABOVE DROP STRUCTURE (AS PER STD. DWG. 2-2-1).



PUBLIC WORKS  
STANDARD DRAWING

REV. DATE: SEPT. 2006

REVISION NUMBER: FOR REVISION TRACKING  
REFER TO STD. DWG. 2-0-2

APPROVED BY DRAWN BY

A.M. A.M.

STD. DWG. NUMBER SCALE

**2-1-6** N.T.S.

MAINTENANCE HOLE DROP STRUCTURE  
INTERNAL ASSEMBLY - EXISTING  
MAINTENANCE HOLES ONLY