



**NOTE**

1. WHERE SECTIONS OF SANITARY SEWERS ARE PROVIDED WITH WATERTIGHT COVERS, VENTS WILL BE REQUIRED EVERY THIRD MAINTENANCE HOLE.
2. ELEVATION OF THE VENT OPENING SHALL BE ABOVE REGIONAL FLOOD LINES AS DETERMINED BY THE CONSERVATION AUTHORITY AND A MINIMUM 1.2m ABOVE GRADE (WHICHEVER IS GREATER).



**PUBLIC WORKS  
STANDARD DRAWING**

REV. DATE: MAY 2009

REVISION NUMBER: FOR REVISION TRACKING REFER TO STD. DWG. 2-0-2

APPROVED BY DRAWN BY

A.P. P.W.

STD. DWG. NUMBER SCALE

**2-1-7** N.T.S.

**MAINTENANCE HOLE VENTING DETAILS**