



- NOTE**
1. REFER TO STANDARD DRAWING 2-5-1 FOR GENERAL NOTES PERTAINING TO PRECAST MAINTENANCE HOLES.
 2. REFER TO STANDARD DRAWING 2-5-2 FOR TYPICAL INSTALLATION OPTIONS AND REQUIREMENTS..
 3. FOR PIPE TO MAINTENANCE HOLE SIZING REFERENCE STD. DWG. 2-5-21.
 4. FOR PIPE SIZE LESS THAN 600mmØ NON PRESSURE DESIGN IS PERMITTED. PIPE SIZES EQUAL TO OR GREATER THAN 600mmØ SHALL BE DESIGNED TO PRESSURE.
 5. FOR TAPERED TOP SECTIONS THE LADDER SHALL ALWAYS BE INSTALLED ON THE SIDE WITH VERTICAL WALL.
 6. FOR PIPES GREATER THAN 600mm DIAMETER LADDER RECESS SHALL BE PROVIDED (STD. DWG. 2-5-10, 2-5-11).

| | | | | |
|--|--|--------------------------------------|-------------------------------------|---|
| | PUBLIC WORKS STANDARD DRAWING | | REV. DATE: AUGUST 2020 | |
| | | | REVISION NUMBER: 2 | FOR REVISION TRACKING REFER TO STD. DWG. 2-0-2 |
| NEW SANITARY SEWER CONSTRUCTION TYPICAL 2400mm DIAMETER PRECAST CIRCULAR MAINTENANCE HOLE DETAILS | | APPROVED BY A.P. | DRAWN BY AINLEY GROUP | |
| | | STD. DWG. NUMBER 2-5-6 | SCALE N.T.S. | |