



NOTE

1. REFER TO STANDARD DRAWING 2-7-1 FOR GENERAL NOTES PERTAINING TO CPP MAINTENANCE HOLES.
2. FROST STRAPS ARE ONLY REQUIRED ON NON AWWA C30X SERIES (CPP) JOINTS AS PER STD. DWG. 2-6-16.
3. 316 STAINLESS STEEL HARDWARE TO BE USED AS A MINIMUM STANDARD.



**PUBLIC WORKS
STANDARD DRAWING**

REV. DATE: AUGUST 2020

REVISION NUMBER: 2 FOR REVISION TRACKING REFER TO STD. DWG. 2-0-2

APPROVED BY DRAWN BY

A.P. AINLEY GROUP

STD. DWG. NUMBER SCALE

2-7-9 N.T.S.

NEW AWWA C30X SERIES (CPP) PRESSURE TESTED SANITARY SYSTEMS

**CPP TO PRECAST CONCRETE RISER
TRANSITION DETAIL**